

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No.F.6/DFS/MS/2022/4200

Dated: 10 /11/2023

To

Sh. Ankur Sharma The Chief Security Officer, Ministry of Defence. 'C' Block, KG Marg. New Delhi.

Sub:- Regarding issuance of fire safety certificate in r/o 1. South Block 2. Defence Offices complex . Kg Marg 3. Sena Bhawan 4. (Air HQ) Vayu Bhawan, New Delhi.

Sir.

This has reference to your letter no.1049/Fire Audit/Security dated 16.10.2023, on the subject cited above in this regard, it is to inform you that the Yau Bhawan (Air Hq) was inspected by the officers concerned of this department on 01/11/2023 in the presence of Sh. Ritesh raj (JE) & Air force officials and the following shortcomings were observed:-

1. Temporary offices are made in the staircase lobby and other open space which may lead to obstruction in case of emergency evacuation.

2. Corridor found encroached at some floors and found blocked by providing door and making of canteen store room which restrict accessibility for the occupants of other offices in case of emergency.

3. Electrical shafts are not sealed horizontally and vertically.

4. Exit signages found inadequate.

Further, Fire safety certificate (FSC) to Defence Office Complex, has already been issued vide letter no. F6/DFS/MS/NDZ/2023/157ated 28.03.2023 and safety audit of South block has already been done and same has been informed vide letter no. F6/DFS/MS/NDZ/2023/157dated 28.03.2023. More over, shortcoming in r/o Sena Bhawan has already been issued vide letter no F6/DFS/MS/NDZ/2022/2795 dated 10.11.22 and compliance of the same are still awaited.

Therefore, you are requested to comply the same for consideration the matter .

Yours faithful

elhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.

2. Dy. Works (B), O/o JS & CAO, 1st floor, A Block, Ministry of Defence, office Complex, Africa Avenue, New Delhi-23.

3. Lr. Col, Adm. & Coord. D-I Wing, Sena Bhawan, New Delhi.