

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6 /DFS/MS/BP/2023/ 224

Dated: 14/11/2023

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi 110002.

Sub: Clearance from fire safety point of view in r/o Block A, Shalimar Bagh,
New Delhi.

Sir,

Please refer your online request ID No.-10117600 dated 03/11/2023, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of addition/alternation of existing building at Block A, Shalimar Bagh, for Forties Hospital Ltd, New Delhi.

Following shortcomings are observed:

1. Compartmentation of floors are not proposed as per clause 8.4.6 of UBBL-2016/NBC-2016
2. Fire Check doors in stores in basements, exits & electrical room are not provided.
3. Fire and life safety arrangements are not proposed on the plan as per NBC part 4.
4. Width of the corridor is not proposed as per clause 7.11.2(e) of UBBL-2016.
5. Fire Tower is not proposed as per clause 9.3.13 (C) of UBBL-2016.
6. Fire Tender movement path is not marked on the plan as per clause 8.2 of UBBL-2016.

Accordingly, the case is hereby rejected.

Yours faithfully

(Atul Garg)
Director
011-23414000