GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE **NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2023/ 4241

DATED: 13 / / 1/2023

(Director

Delhi Fire Service

To,

The Authorized Signatory Maharaja Agrasain Hospital, Plot No. 1, Sector-1, Dwarka, New Delhi.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Maharaja Agrasain Hospital, Located at , Plot No. 1, Sector-1, Dwarka, New Delhi.

Sir.

Please refer to your Form J, dated 16/10/2023 on the subject cited above. In this connection it is to inform to you that the above said building has been re-inspected by the officers concerned of this department on 01/11/2023 in presence of Sh. Manoj Kumar for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

Six meter wide internal road around the building found partially encroached.

The staircases/ passage found partially blocked/ encroached.

3. Fire check door found locked & door closers found missing at some place.

4. Smoke exhaust system in basement & upper floors found nonfunctional & ducts found removed in basement at one place.

5. Automatic fire detection and alarming system found nonfunctional.

MOEFA found nonfunctional.

7. The Sprinkler system to be extended below the falls ceiling at service floor & some other places.

8. Pumps at ground level found nonfunctional in auto mode.

9. Pressurization in lift shaft found nonfunctional.

All the valves at terrace found closed.

11. A floor between 2nd & 3rd floor is being used as service floor and lift lobby at that floor is found removed and the kitchen was found being run at that floor.

12. Fire control room found removed at ground floor.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

Copy to:-

1. The Directorate General of Health Services, F-17, Arjun Gali, Karkardooma, Anand Vihar, New Delhi - 110032.

2. The Joint Director (L&I) Bldg. DDA, Vikas Sadan, INA, New Delhi.