

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F.6/DFS/MS/NDZ/2023/ 4260

Dated 15/11/2023

To,

The Vice President,  
Amarjot Singh Sabharwal,  
Naurang House Owner Association,  
1010, Naurang House, 21 K.G. Marg,  
Connaught Place, New Delhi.

**Sub:- Regarding renewal of FSC in r/o Naurang House, 21 K.G. Marg, New Delhi.**

Sir,

This has reference to your letter no. Nil dated 26/10/2023, on the subject cited above. In this regard, it is to inform that the site was inspected by the officers concerned of this department on 07/11/2023 in the presence of **Sh. Dhairya Taneja (Estate officer)** and the following shortcomings were observed:-

1. Some Fire Check Door found broken and door closer is also not available at some fire check door.
2. Smoke management system in basement found nonfunctional.
3. Detectors are not provided.
4. Electrical shafts are not sealed properly.
5. Hoses are not provided in some hose boxes.
6. MOEEFA & PA system found nonfunctional.
7. Detector panel and flow switch panel are not provided in fire control room.

In view of above, FSC cannot be renewed at this stage, Therefore, you are requested to rectify the above shortcomings at the earliest under intimation to this department. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.