

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2023/SZ/ 549
To

Dated: 15/11/2023

The Principal,
Adarsh Vidya Mandir Public School,
Garhi, Sant Nagar Main Road, East of Kailash,
New Delhi -110065

Sub: Regarding issuance of FSC in r/o Adarsh Vidya Mandir Public School, Garhi, Sant Nagar Main Road, East of Kailash, New Delhi -110065.

Sir,

This has reference to your letter AVMPS/12/23 dated 12/10/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10.11.2023 in the presence of Mr. R.P Tyagi (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The main entrance gate is having width of 2.90 mtr against the required width of 5 mtr.
2. There is one staircase having width of 0.80 mtr against the required two staircase having width of 1.50 mtr each.
3. The widths of classroom doors are having 0.84 mtr against the required width of 1.2 mtr as per UBBL 2016.

The same observation has already been issued and communicated earlier by this department vide letter of even no 281 dated 20.07.2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054