

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/NDZ/School/2023/548

Dated: 15/11/2023

To

The Principal,
Butler Memorial Girls Senior Sec. School,
17, Boulevard Road, Delhi- 110054.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Butler Memorial Girls Senior Secondary School located at 17, Boulevard Road, Delhi- 54.

Sir,

This has reference to email dated 09.10.2023 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 04.11.2023 in the presence of Mrs. Juhi (School Head). During the inspection, following shortcoming was observed:-

1. Fire extinguishers found provided but not functional.
2. Exit signage's are not adequately provided.
3. Domestic LPG Cylinder cannot be used in science lab for any purpose.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service d/c
Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.