



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2023/WZ/ 4267

Dated: 16/11/2023

To,

Sh. Mohit Kumar Goyal,
Crystal Crop Protection Pvt. Ltd.,
B-95, Wazirpur Industrial Area,
Delhi-110052.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Crystal Crop Protection Pvt. Ltd., B-95, Wazirpur Industrial Area, Delhi- 110052.

Sir,

This has reference to your email id dated 07/08/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said industrial building has been carried out by officers concerned of this department on 06.10.2023 to see the compliance of the requisite fire safety measures. Sh. Mohit Kumar Goyal was present at the time of inspection.

During the course of inspection it was observed that the building comprised of 02 Basements, Ground plus Three upper floors while this department had issued FSC vide letter no. F6/DFS/MS/WZ/2020/294 dated 04/08/2020 for 02 Basements, Ground plus Two upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:

1. Staircase and lift are not segregated by fire check doors.
2. Alternate staircase is opening on the terrace.
3. Electrical shafts provided in staircase are not segregated by fire check door.
4. Detectors not provided in cabin rooms.
5. MOEFA found provided but not functional.
6. Main electric pump & Diesel D.G. driven pump was not functional at the time of inspection.
7. The third floor is to be removed/ demolished or the third floor is to be regularized from the building sanctioning authority.
8. Ventilation system was not on auto mode.
9. Sprinkler system shall be extended in left out areas.
10. Temporary structure under the stairs of 2nd basement shall be removed.
11. Garbage shall be removed from ventilation room.
12. Exit signages are not provided in 1st Basement.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Gang)
Director

Ph. 011-23414000

16/11/23