

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

Dated: 15/11/2023

No: F.6/DFS/MS/School/2023/WZ/ 553

To,  
The Principal,  
Goodley Public School,  
BD Block, Shalimar Bagh,  
Delhi-110088.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Goodley Public School (Nursery) located at BD Block, Shalimar Bagh, Delhi-110088.

Sir,

This has reference to your letter number 5/GPS/9/2023/3518 dated 20.10.2023 received via outdoor diary number 7812 dated 25/10/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 07.11.2023 to see the compliance of the requisite fire safety measures. Smt. Jasbir Bhatia (Director) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus Two upper floors. Your request for renewal of FSC is rejected due to the following shortcomings:-

1. MOEFA found provided but not functional.
2. Exit signage's not provided at some strategic locations.
3. Second exit passing through classrooms on 1<sup>st</sup> and 2<sup>nd</sup> floor. It should be separate or an alternate exit shall be provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)  
Director  
Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat ,Delhi-54.