



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 537

Dated: 10 / 11 /2023

To

The Principal,  
Govt. Girls Sr. Sec. School  
(School I'd No-1309034) at  
Adarsh Nagar, Delhi-110033.

**Sub:** - Regarding renewal of fire safety certificate in r/o Govt. Girls Sr. Sec. School (School I'd No-1309034) at Adarsh Nagar, Delhi-110033.

Sir,

Please refer to your letter received through online e-mail dated: 11.10.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was re-inspected by the officer concerned of this department on 31.10.2023 to verify the fire safety measures issued vide NBC Part- IV and observed that as per earlier inspection building was comprised of ground & 03 upper floor. At the time of inspection Sh. Kuldeep Singh (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Some fire extinguisher found not functional.
2. Hose reel hose provided but not functional.
3. Terrace level fire pump capacity of 450lpm provided but not functional.
4. Exit signage and floor signage found removed at strategic locations in the building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)  
Director

Ph:-011-23414000

Copy to:-

1. The principal, Govt. Girls Sr. Sec. School (School I'd No-1309034) at Adarsh Nagar, Delhi-110033.