

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2023/ 4270

DATED: 16/11/2023

To,

The Joint Director,  
DDA, Vikas Sadan, INA,  
New Delhi.

**Subject:** - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Auditorium of National Institute of Malaria Research Building Located at Sector-08, Dwarka, New Delhi-110077.

Sir,

Please refer to your letter No. F13 (982002/BLDG-OCC Dated- 23/10/2023 & Email, dated 01/11/2023 on the subject cited above. In this connection it is to inform you that the above said premises was inspected by the officers concerned of this department on 09/11/2023 along with Sh. Atul (AE DDA), Sh. Shahrookh Ali (AE DDA) from fire safety point of view.

During the course of inspection followings shortcoming & have been observed:-

1. The Smoke exhaust system is provided but found nonfunctional.
2. Hose reel hose and hydrants are provided but found nonfunctional.
3. Automatic fire detection and alarming system are provided but found nonfunctional.
4. MOEFA found provided but found nonfunctional.
5. P A system is provided but found nonfunctional.
6. The main pump, stand by pump & jockey pump are found provided at Ground level but found nonfunctional.
7. Terrace pump are provided but found nonfunctional.
8. Exit signage found not provided.

In view of the above shortcomings Fire Safety Certificate from fire safety point of view cannot be considered. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
(Director)  
Delhi Fire Service

Copy to:-

The Administrative Officer, National Institute of Malaria Research Building Sector-08,  
Dwarka, New Delhi-110077.