

C-30



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 534

Dated: 10 / 11 / 2023

To

The Head of School,
M.C. Primary Co-ed. School (School I'd No-1253118) at
D.T.U. Colony, Near Nanak Piao Gurudwara, Delhi-110033.

Sub: - Regarding renewal of fire safety certificate in r/o M.C. Primary Co-ed. School (School I'd No-1253118) located at D.T.U. Colony, Near Nanak Piao Gurudwara, Delhi-110033.

Sir,

Please refer to your letter No. nil dated: 21.09.2023 received in this department vide outdoor dairy no-6367 dated 21.09.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was inspected by the officer concerned of this department on 26.10.2023 to verify the fire safety measures issued vide NBC Part- IV. At the time of inspection Sh. Alpna Gupta (Incharge) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Width of class room door is 90cm against the requirement of 01m.
2. Hose reel hose not provided.
3. MOEFA system not provided.
4. Terrace level fire pump capacity of 450lpm not provided.
5. Terrace level fire water tank capacity of 10,000ltr not provided.
6. Exit signage and floor signage not provided at strategic locations in the building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully,

(Atul Garg)
Director

Ph: 011-23414000

Copy to:-

1. The Incharge, M.C. Primary Co-ed. School (School I'd No-1253118) located at D.T.U. Colony, Near Nanak Piao Gurudwara, Delhi-110033.