

C-26



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 539

Dated: 10 / 11 / 2023

To

The Principal,
M.C. Primary School
(School I'd No-1253408) at
Lal Bagh New-II, Azadpur, Delhi-110033.

Sub: - Regarding grant of fire safety certificate in r/o M.C. Primary School at Lal Bagh New-II, Azadpur, Delhi-110033

Sir,

Please refer to your letter no. nil dated: 23.09.2023 received in this department vide outdoor dairy no-6628 dated: 26.09.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was re-inspected by the officer concerned of this department on 31.10.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 03 block, one block comprised of ground + first floor & 02 block comprised of pota cabin with 03 class rooms each block. At the time of inspection Smt. Priya Balhara (Incharge) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. The width of access road is not provided to fire engine.
2. The main gate width of 2.60m provided against the requirement of 4.50m.
3. Only single staircase provided at site width of 1.45m against the requirement of 1.50m.
4. Fire extinguisher not provided.
5. Exit & floor signage's not provided at strategic locations in the building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Anil Kiang)
Director

Ph:-011-23044000

Copy to:-

1. The Director of Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.

3/11