



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



C-16

No: F.6/DFS/MS/School/2023/WZ/ 533

Dated: 10/11/2023

To,

The Principal,
MC Primary School,
B-2, Sukhdev Kunj, Keshavpuram,
Delhi-110035.

Sub: - Regarding issuance of Fire Safety Certificate in r/o MC Primary School, B-2, Sukhdev Kunj, Keshavpuram, Delhi-110035.

Sir,

This has reference to your letter no. nil dated 11.10.2023 received via outdoor diary number 7377 dated 13.10.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by the officer concerned of this department on 26.10.2023 to verify the fire safety arrangements provided there in. Smt. Renu Ahuja (Principal) was present at the time of inspection.

During the course of inspection it was observed that school building was comprised of Ground floor plus two upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-


1. First-Aid Hose Reels provided but not functional.
2. Terrace level fire pump provided but not found in auto mode.
3. Exit Signage's not provided.
4. Electrical panel and electric meter found installed under the staircase which should be removed/ shifted to safer place.

You are advised to rectify the above-mentioned shortcomings under intimation to this department..

Yours Faithfully


(Atul Garg)
Director

Ph. 011-23414000


08/11/23

Copy to:-

1. Director of Education, MCD, Civic Center, New Delhi.