

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/School/2023/SZ/ 554  
To

Dated: 17-11-2023

The Principal,  
MCD Primary Model School,  
Dera Village New Delhi 110074  
(School ID 1959092)

Sub: Reg. renewal of Fire Safety Certificate in r/o MCD Primary Model School, Dera Village New Delhi 110074 (School ID 1959092)

Sir,

This has reference with your letter received through email dated 26/09/2023 on the subject cited above. In this regard, it is to inform you that the school premises have been inspected by officer concerned of this department on dated 10.11.2023 in presence of Ms. Nirmla Devi (Principal) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. The First Aid hose reels provided but not functional.
2. Terrace level fire fighting pumps capacity 450 LPM provided but not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, South MCD, Civic Center Minto road, New Delhi 110002