

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F.6/DFS/MS/2023/ 4268

Dated 1.6/.11./2023

To,

Sh. Sohan Kumar Jha (Senior Director M), National Crafts Museum & Hastkala Academy, Bhairon Marg, Pragati Maidan, New Delhi.

Sub:- Regarding issuance of FSC in respect of National Crafts Museum & Hastkala Academy, Bhairon Marg, Pragati Maidan, New Delhi.

Sir.

This has a reference to your letter no. nil dated 11.10.2023, on the subject cited above, it is to inform you that the site was inspected by the officers concerned of this department on 10/11/2023 in the presence of Sh. S.K. Singh, Asstt. Director & Sh. Sachin, Technician and observed that there are three type of occupancy i.e office complex (gr.& Ist floor), residential block (gr. & Ist floor) & Gallery block (ground floor) but only Gallery (assembly occupancy) comes under the purview of Delhi Fire Service and other occupancy such as residential and office complex does not come under the purview of Delhi Fire Service as per DFS Rules 2010 & Act 2007. Accordingly, gallery (assembly occupancy) was inspected from fire safety point of view and following shortcomings were observed:-

1. 02 exits of 1.5m & .75 meter are required in each gallery, whereas one exit of 0.90mter is provided. Hence, one exit of 1.5 meter width is required to be provided in each galley.

 First aid hose reel and hydrant systems are not covering entire area, required to be extended in left out area.

3. MOEFA is not provided.

 Overhead fire water tank of 20,000 liter capacity is provided against the requirement of 25,000 liter.

5. Stand by power supply is not provided to run the fire fighting system.

In view of above, the fire safety certificate / FSC cannot be issued the museum. Therefore, you are requested to rectify the above shortcomings for further consideration in the matter.

(Atul Garg) DIRECTOR Delhi Fire Service

Yours/fai

Copy to:-

1. The Commissioner, MCD, Civic Center, New Delhi.