

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2023/SZ/ 624
To

Dated 15/11/2023

The Dy. Health Officer, MCD,
Public Health Officer,
Aurobindo Marg, Green Park,
New Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Nukkad Cafe And Bar (A Unit Flying Sparrow Hospitality Pvt Ltd) located at HS-7, Third Floor, Kailash Colony Market, Delhi 110048.

Sir,

This has reference to with **MHA Portal 2023101617296 dated 20/10/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03.11.2023 in the presence of Mr. Kanishk Tuteja to verify the fire safety measures installed in the building and observed that restaurant running at 3rd Floor only. During inspection, following points were observed:

- 1 There are two exit doors having width of 1.50 mtr & 1.20 mtr against the required width of 1.50 mtr each as per UBBL 2016.
- 2 First aid hose reel provided but found non-functional.
- 3 Internal hydrant provided but found non-functional.
- 4 Main electrical pumps provided but not connected with tanks.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:

1. The Joint Commissioner of Police (Lic/Branch) 1st Floor PS Defence Colony, New Delhi 110049