

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2023 542

Dated: 10/11/2023

To

The Principal,
Presentation Convent Senior Secondary School,
S. P. Mukherjee Marg, Delhi - 110006.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Presentation Convent Senior Secondary School** located at **S. P. Mukherjee Marg, Delhi - 110006.**

Sir,

This has reference to your letter no. PCS/Acc/2023-24/030 dated 03.10.2023 received in this department, on the subject cited above. In this connection, it is to inform you that the school building was inspected by officer concerned from this department on 25.10.2023 in the presence of Mr. Ratan Mishra (Admin.). During the inspection, following shortcomings were observed:-

1. Fire pump not in auto start mode.
2. Access ladder for overhead water tank should be installed at terrace level.
3. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Encl: As above.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service o/c

Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.