



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/16

No: F.6/DFS/MS/School/2023/WZ/ 551

Dated: 15/11/2023

To,

Er. Amar Chand Meena,
Assistant Engineer (E),
PWD Sub-Division 4,
Edu. Elect. Edn. 1 Div. (N)
Zakhira, Rama Road, Delhi-15.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Sarvodaya Co-ed Vidyalaya (New Building), Prehladpur, Delhi-110042.

Sir,

This has reference to your email id dated 28.10.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 07.11.2023 to ascertain the availability and operability of the fire prevention and fire safety measures, Smt. Mamta Sehrawat (Principal) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus Three upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. MP Hall is having exit width of 1.5 m instead of 2 m.
2. Terrace level fire pump not in auto mode.
3. Building plan and elevation plans are not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director
Ph. 011-23414000

ou n
15/11

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. Principal, Sarvodaya Co-ed Vidyalaya (New Building), Prehladpur, Delhi-42.