

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2023/SZ/ 536

Dated: 10/11/2023

To,

The Principal,
Satyam Public School, 129, Bhagwati Garden Extn.,
Near Kakrola Mode, Uttam Nagar, New Delhi-110059.

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s Satyam Public School, 129,
Bhagwati Garden Extn., Near Kakrola Mode, Uttam Nagar, New Delhi-110059

Sir,

This is in reference to your letter No. SPS/01/2023-24 dated 20/10/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by officer concerned of this department on 04/11/2023 in presence of Smt. Rekha Sharma (Teacher). During the course of inspection it was observed that the building is comprised of ground floor plus three upper floors. The following shortcomings were observed:-

1. First aid hose reel system provided but not functional.
2. Fire pump having 450 lpm provided but not functional.
3. Overhead tank capacity 5,000 ltrs provided instead of 10,000 ltrs.
4. Exit signage's are provided but not sufficient.

Keeping in view of above, the building cannot be considered for issuance of fire safety certificate, at this stage. Therefore you are advised to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully


(Atul Garg)
Director
Delhi Fire Service


Copy:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.