

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/GH/SZ/2023/568

Dated: 17/11/2023

To

The Owner/Occupier
M/s. Golden Deluxe guest house, 12A/7,
WEA, Pusa Lane, Karol Bagh, New Delhi- 110005.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Golden Deluxe guest house located at 12A/7, WEA, Pusa Lane, Karol Bagh, New Delhi- 110005.

Sir,

Please refer to your Online Application No. 2023110718287 dated 08.11.2023 & No. 2023102017538 dated 06.11.2023, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 15.11.2023 in the presence of Ms. Surinder, Manager, to check the functionability of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus two upper floors. Fire safety arrangements such as fire extinguisher, overhead water tank capacity 5,000 lts. etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing building :-

1. Fire Check Doors are not provided.

In view of the above, as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019, the FSC issued vide letter no F6/DFS/MS/GH/SZ/2022/168 dated 29.03.2022, is immediately suspended. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy to :-

1. The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.