

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2023/ 574

Dated: 21/11/2023

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s Hotel Wall Street located at 3660-3665-68-3670 A 3671-C, Netaji Subhash Marg, Delhi-02.

Sir,

This has reference to online application I.D. no. 2023103117959 dated 31.10.2023 on the subject cited above. It is to inform you that the guest house was inspected by the officer concerned from this department on 04.11.2023 in the presence of Manager and it was observed that building is comprised of Ground + 05 upper floors, however the management has submitted an affidavit that no floor above third floor will be used for any purpose. During inspection, following shortcomings were observed:

1. Fire check doors which is required as per gazette notification dated 27.05.2019, not provided.
2. CO detectors with panel and alarm which are required as per gazette notification dated 27.05.2019, not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,

  
(Anil Garg)  
Director

Delhi Fire Service  
Tel: 011-23414000

**Copy to:-**

The Licensee,

Hotel Wall Street located at 3660-3665-68-3670 A 3671-C, Netaji Subhash Marg, Delhi-02.