

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/EH/2023/SZ/ 630

Dated: 20/11/2023

To

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Lite Bite Foods Pvt Ltd (Punjab Grill) at Ground & First Floor, Plot No M-82, Greater Kailash Part - II, Market, New Delhi 110048

Sir,

This has reference to with **MHA Portal ID 2023102717800** dated **28/10/2023** on the subject above. In this connection, it is to inform you that the premise was inspected by the concern nominated authority of this department on 14/11/2023 in the presence of Mr. Nawaz (Manager) to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. There are two exit door having width of 1.10 mtr & 1.40 mtr against the required width of 1.50 mtr as per UBBL-2016.
2. First Aid Hose Reel provided but found non-functional
3. Down comer system provided but found non-functional.
4. Terrace level Fire Pump capacity 450 LPM provided against the required capacity 900 LPM.
5. Overhead tank capacity 25,000 ltrs found empty.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE