

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2023/SZ/ 560
To

Dated: 21/11/2023

The Executive Engineer (E)
DTTDC Ltd New Delhi.
Near Cambridge School, Ring Road,
New Delhi 110065

Sub: Regarding issuance of FSC in r/o Sarvodaya Co-ed Senior Secondary School, Moti Bagh-II, Nanak Pura , New Delhi 110021)

Sir,

This has reference to your letter no. SV/Co.ED/MB-II/NP2022-151 dated 04/07/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.11.2023 in the presence of Mr. Mahesh Kumar to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Newly Constructed Block having ground plus two upper floors served with two staircases only, which do not meet the required travel distance. Additional 02 nos staircase having width of 1.50 mtr not provided.
2. First aid hose reel provided but nonfunctional.
3. Terrace level Fire Pump capacity of 450 LPM x 2 provided but found nonfunctional.
4. Overhead tank capacity 10,000 ltrs found empty.
5. Exit signage not provided.
6. Electrical meter is installed under the staircase is not allowed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.