



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2023/ 4299

DATED: 21/11/2023

To,

The, President,
Shri Ganinath CGHS Ltd.
Plot No-01, Sector-05, Dwarka,
New Delhi - 110075

Subject: - Renewal of Fire Safety Certificate in r/o Shri Ganinath CGHS Ltd. Located at Plot No-01, Sector-05, Dwarka, New Delhi - 110075.

Sir,

Please refer to your letter No SGN/2023/131, dated-22/10/2023 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 13/11/2023 in the presence of Sh. Sudhanshu (Manger) from fire safety point of view.

During the course of inspection followings shortcomings have been observed:-

1. Six meter wide internal road around the building found encroached.
2. Hose reel hose & hydrants found nonfunctional.
3. MOEFA found nonfunctional.
4. PA system found nonfunctional.
5. Hoses and branches are found missing at some places. All hoses, branches & hose fittings must be ISI marked.
6. Terrace pump found nonfunctional.
7. Exit signage's found removed at some places.
8. Communication system in lift car found nonfunctional.
9. Inter connected bridge provided between two blocks is required to be repaired/replaced.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)
(Director)

Delhi Fire Service

Copy to:-

The Joint Director, DDA, Vikas Sadan, INA, New Delhi.