

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6 /DFS/MS/2023/SZ/ 4317
To

Dated: 23/11/2023

Mr. Himanshu Jain (Director)
For IKI Chic Private Limited,
Y-30, Okhla Industrial Area Phase-II,
New Delhi 110020.

Sub: - Regarding issuance of Fire Safety Certificate in r/o IKI Chic Private Limited, at Y-30, Okhla Industrial Area Phase-II, New Delhi 110020.

Sir,

This has reference with your letter no nil dated 31/10/2023 received through outdoor diary no 8256 dated 03/11/2023 on the subject cited above. In this regard, it is to inform you that FSC under Rule 35 of Delhi Fire Service Rules-2010 is issued only for those premise which are referred by building Authority/local authority as specified in section 2 (q) of DFS Act 2007 to this department.

In this regard you are advised to first apply with concern building sanctioning authority with a request to forward following documents to this department to ensure proper implementation of fire prevention & fire safety measures as applicable under Rule 33 of DFS-2010 the said premise/building.

1. Sanctioned/ Completion plans.
2. As built plan through building/local Authority, if sanctioned/Completion plans are not available.
3. Initial date of operation of Occupancy in this building.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg Department) MCD, Jal Vihar Lajpat Nagar, New Delhi 110024.