

C-96

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/GH/2023/SZ/ 576

Dated: 24/11/2023

To

The Joint Commissioner of Police (Licensing)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Airport Hotel & Restaurant, Situated- VIII-148 to 152, Mehram Nagar., New Delhi 110010.

Sir,

This has reference to with **MHA Portal ID 2023103117939 Dated 06/11/2023** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 21.11.2023 in the presence of Mr. S.S. Sharma (Manger) and observed that building comprised of Basement, Ground + 03 upper floors and following shortcomings were observed during inspection :

1. Fire check doors not provided as per clause 7.31 of UBBL 2016.
2. Carbon monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE