## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE NEW DELHI

No F6/DFS/MS/SZ/2023/ 4325

Dated 23 // //2023

To,

The Executive Engineer (E)/ELD-5/DDA Delhi Development Authority, Electrical Division- 05, Central Nursery, Sector -5 Dwarka, New Delhi-110075.

Subject: Issuance of Fire Safety Certificate in r/o Multipurpose Community hall Located at HAF, Pocket-C, Sector - 16B, Dwarka, New Delhi.

Sir,

Please refer to letter No. ED-5/DDA/W-42/577, dated 19/10/2023 & Email dated 23/10/2023 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned of this department on 20-11-2023 in the presence of Mr. Rajiv Gupta (EE DDA) & Alok Parkesh (AE DDA) from fire safety point of view.

During the course of inspection following shortcomings were observed:

1. Six meter wide internal road around the building found not provided.

2. The height of the archway is less than 5mtr.

3. Sealing of electric shaft found not provided.

4. FCD at electrical shaft found not provided.

Smoke exhaust system found inadequate & not interlinked with MOEFA in basement.
The smoke exhaust duct must be extended to open space.

6. Fire extinguishers found not provided in entire building.

Hoses and branches found not provided in hose boxes.

8. All the Pumps at ground level are provided but diesel tank is kept aside & no diesel supply is being given to the pump from diesel tank.

Exit signage found not provided.

- 10. The installation of lift is under progress.
- 13. Building Floor Plans & Battery backup found not provided in Fire Control Room.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered at this stage: You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

Delhi Fire Service

Copy to:

1. The Chief Engineer (Dwarka) / DDA, Manglapuri, Delhi.