

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No.F6/DFS/MS/SZ/2023/ 4332

Dated: 23/11/2023

To,

The President,
Seema CGHS Ltd.
Plot No – 07, Sector – 11, Dwarka, New Delhi.

Subject: - Renewal of Fire Safety Certificate in respect of Seema CGHS Ltd. Located at Plot No – 07, Sector – 11, Dwarka, New Delhi.

Sir,

Please refer to your Email dated -15/11/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned of this department on 21/11/2023 in the presence of Sh. SC Vijay (Vice. President) from fire safety point of view.

During the course of inspection following shortcomings have been observed

1. Six meter wide internal road around the building found encroached/ blocked.
2. Only one ABC type fire extinguisher of 5kg capacity is found provided at each floor against required two fire extinguishers
3. Hose reel hose and hydrants found nonfunctional.
4. Hoses and branches are found missing at some places. All hoses, branches & hose fittings must be ISI marked.
5. All the pumps at ground level found nonfunctional.
6. Exit signage found removed at some places.
7. Communication system is provided in the lift but found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Arul Garg)
Director

Delhi Fire Service.

o/c

22/11/23

Copy to:-

The Joint Director, DDA, Vikas Sadan, INA, New Delhi.