## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001

----

No. F6/DFS/MS/EH/WZ/2023/ 636

Dated: 23 / 1/ /2023

Director

To,

The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. addlep.lic-dl@nic.in

Sub: <u>Issuance of Fire Safety Certificate in respect M/s. The Hazelnut Factory (A Unit of The Food Products LLP) Located at Plot No.-47, Ground Floor, North West Avenue, Club Road, Punjabi Bagh, New Delhi- 110026.</u>

Sir,

Please refer to the online application ID No. 2023110618207 dated 06/11/2023, received through MIIA portal on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 16/11/2023 in the presence of Sh. Kapil (Shift Manager) to check the fire safety arrangements provided in the building.

During inspection, it was observed that the said restaurant is running at ground floor in a building comprised of Ground + 03 upper floors. The fire safety arrangements such as Fire Extinguishers, First-Aid Reels, etc are provided. However the following shortcomings were observed.

- 1. Door size 1.5 X 2 mts are provided but found blocked.
- 2. First-Aid hose reel is not provided.
- MOEFA is provided but not functional.
- 4. Internal hydrant is not provided.
- 5. Main Fire Pump of capacity 450 LPM, is not provided.
- 6. Over Head Water storage tank capacity of 10,000 ltrs is not provided.
- 7. Exit Signage's are not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is not considered at this stage & rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Copy to: -

The Owner/Occupier M/s. The Hazelnut Factory (Λ Unit of The Food Products LLP)
Located at Plot No.-47, Ground Floor, North West Avenue, Club Road, Punjabi Bagh,
New Delhi- 110026. (Online application ID No. 2023110618207 dated 06/11/2023)

2. The Dy. Health Officer, West Zone, South Delhi Municipal Corporation, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id:- (dhowest zone@gmail.com)