

dl6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2023/C.C/268

DATED: 30/11/2023

To,

The Executive Engineer (Building),
MCD Zone officer, Dhansa bus stand,
Najafgarh, New Delhi.

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Coaching center Located at Plot No. 56, Block - B, Sector-12B, Dwarka, New Delhi - 110075.

Sir,

Please refer to Form J, dated 01/11/2023 on the subject cited above. In this connection it is to inform you that the above said building has been inspected by the officers concerned of this department on 23/11/2023 in presence of Sh. Ajay Sharma from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Only one staircase is provided for upper floor and basement against required two staircases of 1.5m clear width.
2. The width of class room doors are found 90 cm to 1 m against required 1m clear width.
3. Smoke management system in basement found not provided.
4. Automatic sprinkler system found not provided in basement.
5. Hose reel hose found not provided.
6. Terrace pump found not provided.
7. Overhead fire water tank of capacity 10000 ltr found not provided.
8. Exit Signage found not provided.
9. Two rooms are constructed at terrace. The rooms must be removed.
10. The electric meter/ panel must not be under the stairs.
11. Detail of students enrolled for the year must be submitted.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)
(Director)

Delhi Fire Service

o/c

Copy to:-

1. Sh. Ajay Sharma, Coaching center Located at Plot No. 56, Block - B, Sector-12B, Dwarka, New Delhi - 110075