

a/24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2023/ 565

Dated: 29/11/2023

To

The Principal,
Anglo Sanskrit V.J. Senior Secondary School,
Darya Ganj, New Delhi - 110002.

Sub:- Regarding renewal of Fire Safety Certificate in r/o Anglo Sanskrit V.J. Senior Secondary School, Daryaganj, New Delhi - 110002.

Sir,

This has reference to your letter no. ASVJ/2023 dated 09.11.2023 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 21.11.2023 in the presence of Mrs. Poonam Bhardwaj (Vice Principal). During the inspection, following shortcomings were observed:-

1. Fire extinguisher's are provided but not functional.
2. Exit signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service
Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.