

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Indl./2023/SZ/ 235
To

Dated: 28/11/2023

The Executive Engineer (Bldg) HQ
Municipal Corporation of Delhi,
9th floor, Civic Center, Minto Road,
New Delhi 110002.

Sir,

Sub: Regarding issuance of Fire Safety Certificate in r/o Plot no. 32, Block-E, Okhla Industrial Area, Phase-II, New Delhi

This has reference with **online ID 10093093 dated 17/11/2023** on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officers concerned of this department on 21.11.2023 along with the team of MCD to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Pressurization of lift/staircase are not done.
2. The width of exit doors at two staircases at all level is provided 1.20 m against the required width of 1.5 m each.
3. Pressurization of lift/staircase are not done.
4. Ventilation system in basement is not working properly and also need to be integrated with fire alarm system (Auto mode).
5. Exit signage not provided at strategic location.
6. The installation work of lift are in under progress/ yet to be installed.

Keeping in view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/ premise in absence of requisite fire safety certificate shall be at the risk and liability of owner/ occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE