

c/77

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/EH/SZ/2023/ 650

Dated:- 30/11/2023

To,

The Owner/Occupier,
M/s. Haldiram Products Pvt. Ltd,
4B/16, Najafgarh Road, Tilak Nagar,
New Delhi- 110018.

Sub: - Regarding renewal of fire safety certificate in r/o M/s. Haldiram Products Pvt. Ltd, located at 4B/16, Najafgarh Road, Tilak Nagar, New Delhi- 110018.

Sir,

Please refer to online application ID 2023111618551 dated 17.11.2023, on the subject cited above. In this regard it is to inform you that the above said eating house running at ground and two upper floor of a building comprised of basement, ground plus two upper floors. The above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on dated 23.11.2023 in presence of Sh. Manish Kumar (Manager).

During the course of inspection the following shortcomings wer observed:-

- 1 Basements stairs found not accessible.
- 2 Terrace found locked.
- 3 Terrace fire pump capacity of 900 LPM found provided but not functional.
- 4 Overhead water storage tank capacity of 5,000 lts found provided against requirement capacity of 10,000 lts.
- 5 Exit signage found removed.

Keeping in view of above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

etc

hr