



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2023/ 639

Dated: 23 /11/2023

To

The Deputy Commissioner (Licensing)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Subject:- Online Application ID No.- 2023102617764 in r/o India Islamic Culture Centre (Dhaba) located at 87-88, Lodhi Estate, New Delhi-110003.

Sir,

This has a reference to online application ID No.- 2023102617764 dated 03.11.2023 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 17.11.2023 in the presence of Mr. N.C. Misra and observed that building comprised of Lower Ground + Ground + 01 upper floors and Dhaba at ground floor only and following shortcomings were observed during inspection :

1. Single exit of width 1.25 mtr. provided against the required two exit of width 1.5 mtr. each.

In addition to above the application needs correction in respect of clear width of door. Accordingly, the applicant may be directed to furnish correct information and compliance of above shortcomings for further necessary action for issuance of Fire Safety Certificate. Hence application is rejected.

Yours faithfully,

(Ravi Garg)  
Director  
Delhi Fire Service

MW

Copy to:-

The Manager,  
India Islamic Culture Centre (Dhaba),  
87-88, Lodhi Estate, New Delhi-110003.