

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2023/4346

DATED: 30/11/2023

To,

The Executive Engineer (Building),  
MCD Zone officer, Dhansa bus stand,  
Najafgarh, New Delhi.

**Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Coaching center Located at Plot No. 47, Sector-12B, Dwarka, New Delhi – 110075.**

Sir,

Please refer to letter No. EE(B)NGZ/23/D-1/1259, dated 30/10/2023 on the subject cited above. In this connection it is to inform you that the above said building has been inspected by the officers concerned of this department on 23/11/2023 in presence of Sh. Joginder from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Only one staircase is provided for upper floors and basement against required two staircases of 1.5m clear width.
2. The width of class room doors are found 90 cm to 1 m against required 1m clear width.
3. Fire Check Door found not provided in basement.
4. The width of corridor/ passage to stairs must not be less than 1.5m
5. Smoke management system in basement found not provided.
6. Hose reel hose found nonfunctional.
7. Automatic fire detection and alarming system found not provided in basement
8. MOEFA & PA system found not provided.
9. Automatic sprinkler system found nonfunctional in basement.
10. Terrace pump found nonfunctional.
11. The capacity of over head fire water tank must not be less than 10000 ltrs.
12. Exit signage found not provided at some places.
13. Electric panel found installed below the staircase in basement.
14. Detail of students enrolled for the year must be submitted.

In view of the above shortcomings issuance of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

(Atul Garg)  
(Director)

Delhi Fire Service

Copy to:- Sh. Joginder, Coaching center Located at Plot No. 47, Sector-12B, Dwarka, New Delhi – 110075.