



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/37 c-38

No: F.6/DFS/MS/School/2023/WZ/ 562

Dated: 29/11/2023

To,
The Principal,
Sarvodaya Kanya Vidyalaya No. 2,
Shakurpur, Delhi-110034.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya No. 2 located at Shakurpur, Delhi-110034.
Sir,

This has reference to your email id dated 07.11.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 21.11.2023 to ascertain the availability and operability of the fire prevention and fire safety measure, Smt. Sumedha Chaudhary (H.O.S.) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus Three upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. The School building is not accessible for fire tenders as 5.5 m wide motor able road is provided against the requirement of 6 m.
2. The main entrance gate is 3.85 m wide against requirement of 4.5 m.
3. Electrical panel found installed under the staircase which has to be removed to a safer place.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)

Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.