



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2023/ 4359

Dated: 01/12/2023

To,

The Authorized Signatory,
Shivam House,
B-2, karampura Comm. Complex,
New Delhi -110015.

Sub: - **Inspection report in r/o M/s. Shivam House Locate at B-2, karampura Comm. Complex, New Delhi -110015.**

Sir,

Please refer to your letter no. Nil dated 14/10/2023 received through outdoor diary no. 11911 dated 03/03/2023 on the subject cited above. In this connection, it is to inform you that the premises/Building was inspected by the officer concerned by this department on 23/11/2023 in the presence of Sh. Amrik Singh to check the shortcomings already issued vide letter no. F6/DFS/MS/WZ/2023/150 dated 25/01/2023, F6/DFS/MS/WZ/2023/697 dated 06/04/2023 & F6/DFS/MS/WZ/2023/1161 dated 02/06/2023.

The Status of the Shortcoming is as under:-

S. no.	Shortcomings	Status
1.	Fire Check Doors are found removed at some places.	Not Rectified
2.	First Aid hose reel provided but not functional.	Rectified
3.	Automatic fire detection and alarming system provided but not functional.	Rectified
4.	MOEFA is provided but not functional.	Rectified
5.	Public address system provided but not functional.	Not Rectified
6.	Automatic sprinklers system is provided but not functional.	Rectified
7.	Internal Hydrants is provided but not functional.	Rectified
8.	Main Pump 900 lpm is found removed.	Rectified
9.	Overhead water storage tank capacity 50,000 ltrs are provided but uses as a domestic purpose.	Rectified
10.	Exit sinages found removed.	Not Rectified

In view of above, application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(A. Singh)
Director

Copy To: -

1. The Executive Engineer (Building), MCD, Karol Bagh Zone, Anand Parbat, New Delhi.
(Email Id: - eepwddelhim132@gmail.com)

29/11
29/11/2023