

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/WZ/2023/ 649

Dated: 29/11/23

To,

Mr. Anil Garg,  
House No.102-103,  
2<sup>nd</sup> floor, Pocket-5, Sector-22, Rohini,  
Delhi-110085.

**Sub:** Issue of FSC in r/o M/s Caffeinated Enterprises, Shop No.604, 6<sup>th</sup> floor, Unity One MLCP, (Rohini West Metro Station) Complex, Delhi-110085.

Sir,

Kindly reference to online application No.2023102117606 dated 30.10.2023, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 14.11.2023, in presence of **Sh. Dharam Thakur (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width of doors is 1.0 & 1.10 mtr against the required width of 1.5m each.
2. Fire extinguishers are not provided.
3. Smoke management /ventilation are not provided.
4. The required exit signage are not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt)  
[p://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](p://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)

DIRECTOR

PH: 011-23414000

Copy to:

MHA Portal ID-2023102117606 dated 30.10.2023

ok  
24