



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

75  
आज़ादी का  
अमृत महोत्सव

No. F. 6. / DFS / MS / BP / CGHS/2023/ 237

Dated: 30 /11/2023

To,

The Dy. Director (L&I) Bldg.,  
Delhi Development Authority,  
Vikas Sadan, INA,  
New Delh-110023.

**Sub: Clearance of online building plans from fire safety point of view belonging to Vishrantika CGHS Ltd. at Plot No. 5A, Sector-3, Dwarka, New Delhi for addition/alteration.**

Sir,

Please refer your online file No. DW3/0099/2023 dated 23.11.2023 on the subject cited above. In this connection it is to inform you that the referred online building plans have been examined by this department from fire and life safety point of view and observed following shortcomings:

1. Width of staircases is not mentioned on plans.
2. 6.0 meter wide fire tender movement road is not marked all around the high rise blocks.

Therefore, proposal is rejected.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR  
Ph. 011-23414000

