

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No.F6/DFS/MS/SZ/2023/ 4386

Dated: 07/11/2023

To,

The President,
Dharam Vihar CGHS Ltd.
Plot No – 02, Sector – 10, Dwarka, New Delhi.

Subject: - Renewal of fire safety certificate in r/o Dharam Vihar CGHS Ltd. Located at Plot No – 02, Sector – 10, Dwarka, New Delhi.

Sir,
Please refer to your letter No-FCS/Administrator/2023/05 dated -19/10/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned of this department on 29/11/2023 in the presence of Sh. Jagmohan Singh (Manager) from fire safety point of view.

During the course of inspection following shortcomings have been observed

1. Six miter wide internal road around the building found not provided.
2. Width of Staircase for upper floors must not be less than 1.25m.
3. Hose reel hose and hydrants found nonfunctional
4. MOEFA found nonfunctional.
5. PA system found nonfunctional.
6. Terrace Pump of 450 lpm with 40m head found nonfunctional and not in auto mode.
7. Exit signage found removed at some places.
8. Communication system & fireman ground switch are provided in the lift but found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service.