

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/FH/2023/SZ/241

Dated: 07/12/2023

To

The Joint Commissioner of Police,
Lic/Unit 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Shagun Farm located at
Khasra No 25/5/6/15/16 Village-Jonapur, Mehrauli, New Delhi

Sir,

This has reference to with MHA Portal ID 2023111318461 dated 20-11-2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 01.12.2023 in the presence of Mr. Raman (Manager) to verify the fire safety measures installed in the building and observed that the Farm House comprised of Basement, (Vacant) and Ground floor only. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The First Aid Hose reel provided but found non-functional.
2. The Internal Hydrant provided but found non-functional.
3. Fire Fighting pumps are provided but found non-functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE