

C/43

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F.6/DFS/MS/SZ/2023/School | 580

Dated: 07/12/ 2023

To,

The Principal,  
Sulabh International Centre for Action Sociology,  
Sulabh Bhawan, RZ-83, Mahavir Enclave,  
New Delhi-110045.

**Subject: Renewal of Fire Safety Certificate in r/o Sulabh International Centre for Action Sociology Located at Sulabh Bhawan, RZ-83, Mahavir Enclave, New Delhi-110045.**

Sir,

Please refer to your Email dated 17/11/2023 on the subject mentioned above. In this connection it is to inform you that the premises was re-inspected by the officer concerned of this department on 28/11/2023 in the presence of Sh. Anil Kumar (Secretary) from fire safety point of view.

**The following shortcoming was observed during the time of inspection:-**

1. Some rooms have been added at second floor. The rooms must be removed.
2. The length of Hose reel hoses must be increase so that it may cover entire area at each floor.
3. Terrace pump found nonfunctional in auto mode.
4. Overhead fire water tank of capacity 5000 ltr capacity is found provided against required 10000 ltr.
5. Exit signage found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
Director  
Delhi Fire Service.

O/c

Copy to; - Directorate of Education Old Secretariat Delhi - 110054.