



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी का  
अमृत महोत्सव

416

No. F6 /DFS/MS/School/NDZ/2023/ 567

Dated: 07/12 /2023

To,

The Principal  
Bhai Lalo Public School,  
12/192-A, Geeta Colony,  
Delhi-110031.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Bhai Lalo Public School, located at,  
12/192-A, Delhi-110096**

Sir,

This has a reference to your Outdoor dairy no. 8452 dated 09/11/2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 20/11/2023 in the presence of Mrs. Mamta Malhotra (Principal) and observed that building comprised of ground plus three upper floors and following shortcomings were observed during time of inspection:

1. One staircase of width 1.70 meter provided against two staircases of width 1.50 meter each.
2. Hose reel hose not functional.
3. Fire pump of 450 LPM not provided.
4. Overhead tank capacity 10,000 liters not provided.
5. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, D- Block Anand Vihar, Delhi-110092.