



C/39.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2023/School/ 573

Dated: 07/12/2023

To

The Principal,
Govt. Sarvodaya Kanya Vidyalaya Old Block
Magazine Road, Majnu Tilla Delhi-110054.

Sub: - Regarding issuance of fire safety certificate in r/o Govt. Sarvodaya Kanya Vidyalaya Old Block, (School I.D No.1207112) at Magazine Road, Majnu Tilla Delhi-110054.

Sir,

Please refer to your letter No. SKV/MR/1319 dated 26.10.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 22.11.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 03 upper floors only. At the time of inspection Sh. Manoj Kumar (Incharge) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire Extinguisher provided but not functional.
2. Hose reel hose provided but not functional.
3. Internal hydrant provided but not functional.
4. Terrace level fire pump capacity of 450lpm provided but not functional and damaged condition.
5. Terrace level fire water tank capacity of 10,000ltr found damaged condition.
6. Exit signage and floor signage found removed at strategic locations in the building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Ajul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.