

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 568

Dated: 07 /12 /2023

To

The Principal Panacea National Public School, Libaspur Road Siraspur, Delhi-110042.

Sub: - Regarding issuance of fire safety certificate in r/o Panacea National Public School located at Libaspur Road Siraspur, Delhi-110042. Sir.

Please refer to your letter no. PNPS/2023/DFS/059 dated 26.09.2023 received in this department vide outdoor dairy no.7231 dated 11.10.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 20.11.2023 to check the existing fire safety measures and observed that as per earlier Fire Safety Certificate issued by this department vide letter of even no.F6/DFS/MS/School/2013/WZ/1354 dated 27.12.2013 the building was comprised of ground & first floor only. Now the school management has been added one more floors the building composition is Ground & 02 upper floors only. At the time of inspection Sh. Lalit Kumar (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- There is 2nos. of staircases provided with of 1.10m each against the requirement of 1.50m each.
- 2 Fire extinguisher provided but found not functional.

3 Hose reel hose not provided.

4 Terrace level fire fighting pump capacity of 450lpm not provided.

5 Terrace level fire water tank capacity of 10,000ltrs not provided.

Exit signage not provided at strategic locations in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi