

c/81

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/Restaurant/2023/ 661

Dated: 07/12/2023

To,

Mr. Abhishek Mittal,  
House No.A-43, Ground floor,  
Sarita Vihar,  
New Delhi-110076.

**Sub:** Issue of FSC in r/o M/s Pizza Hut Restaurant (A Unit of M/s Devyani International Ltd.) Shop No.91, Plot No.17, Mangalm Place, Sector-3, Rohini, Delhi-110085.

Sir,

This is in reference to your online application No. 2023111018433 dated 17.11.2023 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 29.11.2023, in presence of **Mr. Jitender** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 02nos. of fire extinguishers of ABC type provided against the required 04 no's of ABC / Co2 type 2.5 kg capacity required to be provided.
2. First-Aid hose provided near to restaurant found removed.
3. Manually operated electric fire alarm found missing.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules)  
[/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

  
(Atul Garg)  
**DIRECTOR**  
Ph; 011-23414000

Copy to:-

MHA Portal ID- 2023111018433 dated 17.11.2023