

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI – 110001

NO. F6/DFS/MS/SZ/2023/CC 272

DATED: 04/12/2023

To,

The Executive Engineer (Building), MCD Zone officer, Dhansa bus stand, Najafgarh,New Delhi.

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Coaching center Located at Plot No. 58, Sector-12B, Dwarka, New Delhi – 110075.

Sir,

Please refer to DFS outdoor diary No. 8124, dated 01/11/2023 on the subject cited above. In this connection it is to inform you that the above said building has been inspected by the officers concerned of this department on 23/11/2023 in presence of Sh. Sudhakar Bharti from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-.

- Only one staircase is provided for upper floor against required two staircases of 1.5m clear width.
- 2. Two staircase of 1m width is provided for basement against required two staircases of 1.5m clear width.
- 3. The width of class room doors must not be less than 1m clear.
- 4. All the corridors/passages lead to stairs must have 1.5 m width.
- 5. Smoke management system in basement found not provided.
- 6. Automatic sprinkler system found not provided in basement.
- 7. Hose reel hose found not provided.
- 8. Terrace pump found not provided.
- 9. Overhead fire water tank of capacity 15000 ltr found not provided.
- 10. Exit Signage found not provided.
- 11. The electric meter/ panel must not be under the stairs.
- 12. Detail of students enrolled for the year must be submitted.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation to this department for further consideration in the matter.

(Director)

Copy to:-

 Sh. Virender Kumar Vats, Coaching center Located at Plot No. 58, Sector-12B, Dwarka, New Delhi – 110075.