

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/Ind./2023/SZ/ 4404  
To

Dated: 07/12/2023

M/s Alankrit Handicrafts Pvt Ltd.,  
208, Okhla Industrial Area Phase- III,  
New Delhi 110020

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Alankrit Handicrafts Pvt Ltd., 208, Okhla Industrial Area Phase- III, New Delhi 110020.

Sir,

This has reference to Email dated 23-08-2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 30.11.2023 in the presence of Mr. Shivakant Jha (Admin) to verify the fire safety measures installed in the building and observed that the industrial is running at 02 tier Basement, Ground plus two upper floors. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire Check door found removed.
2. First aid hose reel provided but found nonfunctional.
3. Automatic sprinkler system provided but found nonfunctional.
4. Internal hydrant provided but found nonfunctional.
5. Fire Pumps are not on auto mode.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg) SDMC Jal Vihar, Lajpat Nagar, New Delhi 110024.