

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/Hospital/2023/SZ/ 4414

Dated: 11/12/2023

To,

The Director,
M/s Bhagat Hospital,
D-2/48-49, Janakpuri, New Delhi 110019.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. M/s Bhagat Hospital, situated at D-2/48-49, Janakpuri, New Delhi 110019.

Sir,

This has reference to your Letter No. Nil 8973 dated 21/11/2023 on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the hospital on 01/12/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Mahim Bhagat (Director) was present and it was observed that the hospital building is comprised of basement, ground plus three upper floors and have following shortcomings.

1. Second staircase shall be extended upto 1.5 m from basement to terrace.
2. Ramp of 1.30 m is provided from ground floor to first floor instead of 1.5 m.
3. Fire check doors not provided.
4. Smoke management system not provided.
5. First aid hose reels are provided but not functional.
6. Sprinkler system & Automatic Fire Detection system is not provided in the entire building.
7. Wet riser system not provided.
8. One electric and one diesel pump of capacity 1620 LPM and one jockey pump of capacity 180 LPM are not provided.
9. Under ground tank capacity 50,000 liter provided in place of 75,000 liters.
10. Exits signage's are not sufficient.
11. Fireman's Grounding Switch & Lift Signage not provided.
12. Domestic connections are provided in OHT.

Hence issuance of Fire Safety Certificate from fire safety point of view can not be considered at this stage in the interest of public safety. However, the management of the hospital is advised to rectify the above short comings with the intimation to this Department for issuance of Fire Safety Certificate.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. MS, Nursing Homes, DGHS, Govt of NCT of Delhi, S-1, 3rd Floor, School Block, Shakarpur, Delhi-110092.