

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Indl./2023/SZ/243
To

Dated: 08/12/2023

The Executive Engineer (Bldg) HQ,
Municipal Corporation of Delhi,
9th floor, Civic Center, Minto Road,
New Delhi 110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o Plot No. 39, Block-Z, Okhla Industrial Area, Phase-II, New Delhi 110020

Sir,

This has reference with **online ID 10080674 dated 28/11/2023** on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officers concerned of this department on 05.12.2023 along with Mr. Avinash Raj JE (Bldg) MCD & Mr. Naveen Kaul AE (Bldg) MCD to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Ventilation system in basement is not working properly and also need to be integrated with fire alarm system (Auto mode).
2. First aid hose reel provided but found nonfunctional.
3. Automatic sprinkler system provided but found nonfunctional.
4. Fire fighting pumps are not on auto mode.
5. Exit signage not provided at strategic location.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE